

PUBLIC NOTICE

Franklin Water Heating

NOTICE OF INTENT TO GRANT A PERMIT AUTHORIZING USE OF WATER FOR GEO- THERMAL HEATING AND COOLING PURPOSES IN FRANKLIN COUNTY, IOWA

Notice is hereby given that pursuant to Iowa Code Chapter 455B, there is now on file with the Iowa Department of Natural Resources, Water Supply Engineering Section, 502 E 9th Street, Des Moines, Iowa 50319 the application as described below.

West Fork Community School District (Log No. 31,478) requests a permit modification authorizing withdrawal of water from one 8-inch diameter Devonian supply well, about 435 feet deep, and injection of said water with one 8-inch diameter Devonian injection well, about 438 feet deep, located on land generally described as the NW $\frac{1}{4}$ of the SW $\frac{1}{4}$ of Section 4, T93N, R20W, Franklin County, Iowa, in the maximum quantity of 45 million gallons per year at a maximum rate of 280 gallons per minute throughout each year for use in the HVAC system at the Wellness Center, located on said land at 419 West Park Street, Sheffield, Iowa. Water Use Permit No. 10,100 presently authorizes withdrawal and injection of water in the maximum quantity of 29 million gallons per year for said system.

The Department has determined that this use of water conforms to the relevant criteria (Iowa Code Chapter 455B and Iowa Administrative Code Chapter 567) and recommends the permit be granted. A copy of the summary report for this application is available upon a request to the department at the address listed above. Comments on the report and on this use of water must be received by November 17, 2021, and should be addressed "ATTN.: Water Supply Engineering Section" and should specify the applicant's log number. (By Jim Neleigh)

Published in The Sheffield Press on
Thursday, Oct. 28, 2021
